



**CALIFORNIA DEPARTMENT OF FORESTRY and FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL**

**REGISTERED FLAME RESISTANT PRODUCT**

**Product:**

**NOFIRE A18**

**Registration No.**


**C-20501**

**Product Marketed By:**

**NOFIRE TECHNOLOGIES INC  
21 INDUSTRIAL AVE  
UPPER SADDLE RIVER, NJ 07458**

This product meets the minimum requirements of flame resistance established by the California State Fire Marshal for products identified in Section 13115, California Health and Safety Code.

The scope of the approved use of this product is provided in the current edition of the **CALIFORNIA APPROVED LIST OF FLAME RETARDANT CHEMICALS AND FABRICS, GENERAL AND LIMITED APPLICATIONS CONCERNS** published by the California State Fire Marshal.



Deputy State Fire Marshal

**Expire: 6/30/2011**

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 2280-1681:0100 Page 1 of 1

**CATEGORY:** 2280 – COATING MATERIALS (FLAME SPREAD)

**LISTEE:** NO FIRE TECHNOLOGIES, 21 Industrial Ave., Upper Saddle River, NJ 07458  
Contact: Samuel Gottfried (201) 818-1616 Fax (201) 818-8775  
Email: nofire@nofire.net

**DESIGN:** No Fire A18 Water based intumescent coating for interior use on unfinished dimensional lumber of douglas fir species. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** Flame spread 10, Smoke Developed 55

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, product label and UL label.

**APPROVAL:** Listed as a coating material for application to wood wall and ceiling surfaces to reduce flame spread. Approval limited to interior wall/ceiling surfaces when the coatings are applied at the minimum rate of 165 ft<sup>2</sup>/gal per coat. Authority having jurisdiction should be consulted prior to installation.

11-09-2006 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **July 01, 2010**

Listing Expires **June 30, 2011**

Authorized By: **FRANCIS MATEO, Program Coordinator**  
Fire Engineering Division